



AURANGABAD MUNICIPAL CORPORATION

FIRE BRIGADE

TELEPHONE NO-2334000-40FAX No-2331444

Order No:AMC/FIRE/144/2020

Date 14/08/10/2020

To,
Sau. Madhuri Vijay Jadhav,
Vijayalaxmi Bahuddeshiya Pr Greenfield International,
English School Building, Gut No. 72/1, At. Daulatabad T Point,
Sharanapur Dist. Aurangabad.

Sub:- Fire NOC Renwal is issued to the Vijayalaxmi Bahuddeshiya Pr Greenfield International, English School Building, Gut No. 72/1, At. Daulatabad T Point, Sharanapur Dist. Aurangabad.

Ref:- 1) Your letter dated 04/03/2017 2) Final Noc on dated 04/03/2017
3) Your Letter dated 21/09/2020 4) CFO Inspection on dated 21/09/2020

With Reference to the above subject. Fire NOC Renwal is issued to the Vijayalaxmi Bahuddeshiya Pr Greenfield International, English School Building, Gut No. 72/1, At. Daulatabad T Point, Sharanapur Dist. Aurangabad. Plot area 14633.75 sq. meter.

Sr No	Building Type	Height of Building	Floors	Area Of Plot	Builtup Area In Sq.m
1	Vijayalaxmi Bahuddeshiya Pr Greenfield International, English School Building	14.75	B+ G + 2Floors	14633.75	2125.00

Following Fire prevention and Fire protection & Fire Fighting measures subject to the is Vijayalaxmi Bahuddeshiya Pr Greenfield International English School Building is provided.

1. 6.00 Mtr. Open space all around the building is provided for the movement of fire tender and which will carry 25 tons. weight capacity.
2. Overhead water tank 15000 lit capacity -01 Nos are Provided & Fire Pump with the of Suitable capacity for building shall be provided.
3. Fire service inlet 4 way incoming shall be provided.
4. Down Commer having outlet on all floors with Hose pipe / Branch shall be provided.
5. 04 Nos. Hose reel of 100 feet on all outlets is provided.
6. Fire Extinguisher of ABC - 06 Kg - 09 Nos. & Co2- 4.5 Kg-02 Nos of suitable capacity / quantity is provided.
7. Main Staircase 2.00 Mtr Width is provided
8. This Certificate shall be treated valid for a period of one year from the date of issue of Fire Noc.
9. Fire Noc is valide for one year & Noc should be renewed each year.

For Vijaya Laxmi Bahuuddeshiya Prashastan


M. Jadhav
Authorized Signatory

S. Jadhav
Principal
Green Field International
Sharanapur, Daulatabad T-Point
Tq. Dist. Aurangabad

As per BMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention & Life safety Measures Act 2006 reference to above subject Fire NÔC Renwal is issued to the Sau. Madhuri Vijay Jadhav, Vijayalaxmi Bahuddeshiya Pr Greenfield International, English School Building, Gut No. 72/1, At. Daulatabad T Point, Sharanapur Dist. Aurangabad.


10-20
Chief Fire Officer
Fire Brigade
Municipal Corporation Aurangabad

Copy to:- A D.T.P AMC, Aurangabad.

For Vijaya Laxmi Bahuddeshiya Praxman

Authorised Signatory


Principal
Green Field International
Shamapur, Daultabad T-Point
Tq. Dist. Aurangabad

As per BMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention & Life safety Measures Act 2006 reference to above subject Fire NOC Renwal is issued to the Sau. Madhuri Vijay Jadhav, Vijayalaxmi Bahuddeshiya Pr Greenfield International, English School Building, Gut No. 72/1, At. Daulatabad T Point, Sharanapur Dist. Aurangabad.


10-20
Chief Fire Officer
Fire Brigade
Municipal Corporation Aurangabad

Copy to:- A D.T.P AMC, Aurangabad.

For Vijaya Laxmi Bahuddeshiya Praxman


Authorised Signatory

Principal
Green Field International
Sharnapur, Daultabad T-Point
Tq. Dist. Aurangabad